



Indian River County Fire Rescue
Fire Prevention Bureau
1801 27th Street Building A
Vero Beach, FL 32960
Phone: 772-226-1880
Fax: 772-978-1848
fireprevention@ircgov.com

SPECIAL EVENT APPLICATION

Date: _____

Name of event: _____

Organization holding event: _____

Address of event: _____

Date & time of event: _____

Contact person(s): _____ Phone(s): _____

Date & time ready for inspection: _____

Email: _____ FAX: _____

STANDARD SPECIAL EVENT FEE \$30.00
FIREWORKS SALES AND DISPLAY (PYROTECHNICS) FEE \$100.00
MAKE CHECKS PAYABLE TO INDIAN RIVER COUNTY FIRE RESCUE

Only items that are in accordance with applicable Florida Statutes and County Ordinances will be permitted to be sold in Indian River County.

FIREWORKS ARE PROHIBITED FOR RETAIL SALE IN INDIAN RIVER COUNTY.

OFFICIAL USE ONLY

Permit #: _____ Inspector: _____

Fees Paid: _____ Issued by: _____



Indian River County Fire Rescue
Fire Prevention Bureau
1801 27th Street Building A
Vero Beach, FL 32960
Phone: 772-226-1880
Fax: 772-978-1848
fireprevention@ircgov.com

SPECIAL EVENT COOKING QUESTIONNAIRE

1. Location of proposed cooking? (Identify on map).
2. Is any cooking taking place under a tent? (No deep frying permitted).
3. Number, type and size of cookers?
4. Type of heating source? (LP, Electric, Charcoal etc).
5. Please list any cooking trucks, trailers or structures.

Any vendor found in non-compliance with the Florida Fire Prevention Code and any associated NFPA Codes shall be issued a cease and desist order by the Fire Marshal until the vendor complies.

I have read, understand, and will comply with all requirements of the Special Event requirements

Applicant Signature

Print Name



Indian River County Fire Rescue
Fire Prevention Bureau
1801 27th Street Building A
Vero Beach, FL 32960
(772) 226-1880
(772) 226-1841 fax
fireprevention@ircgov.com

SPECIAL EVENT PERMIT HOLDER REQUIREMENTS

General: A permit may be issued contingent upon the following requirements. **Please read carefully and initial or check each section and sign at the bottom.** The permit applicant shall be responsible for the following items mentioned herein:

- SITE:** A sketch or map of the site showing locations of all tents and vendors must be provided to the Bureau at time of application. A vendors checklist must be completed by each vendor and either submitted to the Bureau prior to the event or available to the inspector at the time of inspection.
 - TENTS:** All tents shall have a **Flame Retardant or Resistant Certificate (Tag or Paperwork)** on-site and/or submitted with the application. A minimum 10 ft. of clearance between rows of side-by-side tents shall be provided (walkway). Shade canopy's smaller than 10x10 without sides may be approved for use on a case by case basis. No smoking in any tent.
 - EMERGENCY EGRESS:** For every 100 ft. row of tents, an emergency exit walkway is required that is at least 5' wide.
 - COOKING TENTS:** Tents up to 20x20 are allowed to have cooking (**APPROVED APPLIANCES**) along the edges of the tent. LP gas tanks must be secured in place (max cap 20lbs.) Fire Extinguisher must be readily available. Any LP tanks larger than 20 lbs. shall be secured 10 ft. from tents with gas lines secured. All cooking vendors shall have a 10ft. separation from all other non-cooking tents and/or vendors. **NO DEEP FRYING UNDER TENTS!**
 - FIRE EXTINGUISHERS:** Every vendor is recommended to have at least one extinguisher. At least one currently certified and tagged, or within one year of manufacture date, extinguisher is required every 75' along event walkways. All vendors who are cooking and/or using generators are required to have at least one **5lb ABC currently certified and tagged, or within one year of manufacture date, (2A10BC) extinguisher**. All vendors who are deep fat frying are required to have at least one currently tagged **Class K extinguishers**.
 - SEATING:** Seating and chair arrangements shall be approved by the Bureau prior to the event and have a minimum of 3ft. wide walkways to all exits in the tent. Tents with an occupant load of over 49 are required to have at least 2 exits.
 - LARGE TENTS:** For tents 20x20 or larger, If enclosures (sides) are used, exits shall have exit signage. If the tent is used at night, exit signs shall have attached emergency lighting and be AC and DC powered. All tents 20x20 or larger must have NO SMOKING signs that are visible.
 - OPEN FLAMES:** All open flames, fireworks or fuel-fired lighting or devices are prohibited in any tent or similar enclosure unless prior approval from the Bureau is obtained.
 - STORAGE:** Use or handling of flammable liquids or gases shall be prohibited at the site unless specifically approved and inspected by this Bureau.
 - FLOOR/DECOR:** No hay, straw, shavings or similar materials shall be permitted to be used within any structure, tent or canopy. Exceptions: Pre-approved flame retardant treated materials or livestock bedding/fodder.
 - GENERATORS:** Generators shall be on level ground, secured, and safely arranged and isolated from the occupants/general public. Exhaust shall be directed away from combustible material(s), people and/or animals. Spare fuel shall be stored in an approved container at a safe distance from generator. **NO HOT FUELING!** Fire extinguisher required.
 - ELECTRIC:** wiring and lighting shall be free of damage. All electrical equipment shall be isolated from the occupants/general public in a safe manner. All electrical connections, switches and fuses shall be in secured in approved enclosures per the electric code NFPA 70.
 - COOKING:** All food cooking concession trucks, trailers and structures of rigid construction must have a currently tagged commercial ventilation, and extinguishment/suppression system if required per the FFPC and NFPA 96.
- Code References: Florida Fire Prevention Code (FFPC), NFPA 1, NFPA 96, NFPA 70, NFPA 101, & NFPA 102.*
- Any vendor(s) found not complying with the referenced Fire Prevention & Life Safety Codes may be issued a cease and desist order by the Fire Marshal which will remain in effect until compliance is made.**
- I have read, understood, and will comply with all listed Checklist items and Code requirements.**
- X _____